

9.4.8 Ship-sourced pollutants reception facilities in marinas code

9.4.8.1 Application

- (1) This code applies to all private marina development with six or more berths, located outside Strategic Port Land, Core Port Land and State Development Areas.

9.4.8.2 Purpose

- (2) The purpose of this code is to ensure that all marina development facilitates the installation, maintenance and availability of ship-sourced pollutants reception facilities to prevent marine pollution.

9.4.8.3 Criteria for assessment

Table 9.4.8.3.a – Ship-sourced pollutants reception facilities in marinas – assessable development

Performance outcomes	Acceptable outcomes
<p>PO1 Marina development provides facilities for the handling and disposal of ship-sourced pollutants.</p>	<p>AO1.1 Common user facilities for the handling and disposal of ship-sourced pollutants, including oil, garbage and sewage shall be provided at a suitable location at the marina.</p> <p>and</p> <p>Facilities shall be designed and operated at all times to ensure the risk of spillage from operations is minimised.</p> <p>and</p> <p>Appropriate equipment to contain and remove spillages shall at all times be kept stored in a convenient position near the facility and be available for immediate use.</p> <p>and</p> <p>All boats visiting the marina shall be able to use the ship-sourced pollutants reception facilities.</p> <p>Editor's note – Refer to Australian and New Zealand Environment and Conservation Council (ANZECC), 1997, Best Practice Guidelines for Waste Reception Facilities at Ports, Marinas and Boat Harbours in Australia and new Zealand.</p> <p>Note – The reception facilities require compliance assessment under the Plumbing and Drainage Act 2002. The plumbing compliance assessment process will ensure that the proposed facilities address 'peak load'.</p> <p>AO1.2</p> <p>Where practical, the marina pollutant reception facility will be connected to the water service provider's sewerage or other waste reception infrastructure.</p> <p>Note – The reception facilities require compliance assessment under the <i>Plumbing and Drainage Act 2002</i>. The plumbing compliance assessment process will ensure that the proposed facilities address 'peak load'.</p>